


NOTE:

- TEMPORARY BRACING MAY BE REQUIRED TO RESIST PRESSURES FROM THE WET CONCRETE PLACED BEHIND THE VERSA-LOK UNITS DURING CONSTRUCTION
- CONCRETE FOUNDATIONS AND STEEL REINFORCEMENT SHOULD BE DESIGNED BY A QUALIFIED ENGINEER
- MINIMUM FROST DEPTH (Y) VARIES WITH REGION

20" STANDARD COLUMN SECTION
REINFORCED COLUMN
SCALE: NONE

THESE PRELIMINARY DETAILS ARE INTENDED AS AN AID IN DESIGNING ATTRACTIVE, DURABLE RETAINING WALLS WITH VERSA-LOK UNITS. FINAL DETERMINATION OF THE SUITABILITY OF ANY INFORMATION OR MATERIAL FOR THE USE CONTEMPLATED, AND ITS MANNER OF USE, IS THE SOLE RESPONSIBILITY OF THE USER. A FINAL PROJECT SPECIFIC DESIGN SHOULD BE PREPARED BY A QUALIFIED, LICENSED, PROFESSIONAL ENGINEER.



VERSA-LOK®
Retaining Wall Systems

(800)770-4525 fax(651)770-4089
6348 Hwy36 Ste1, Oakdale,MN 55128 **Solid Solutions™**

VERSA-LOK STANDARD DETAILS

20" REINFORCED COLUMN
SECTION

SCALE: 1/2"=1'

DRAWN BY: PPS

CHECKED BY:

DATE: 10/2007

DWG. NO.
strnd reinforced column section